

Product: BHU LINEMED TRIANGLE LED P-4400-2200-ON-2-B-B-3-B E OPTICS-3L/PLX 53 840 L=1250MM Index: 19.4060.1221.53




Description

Modern lighting in hospital wards, outpatient clinics and other health care institutions is not just the question of general ambient lighting. Modern buildings require special devices which combine elements of lighting together with life rescuing equipment in one installation. The bed head system is certainly a device of this kind. With Its modern design and high quality material used for its construction as well as possibility of installation to it different kinds of equipment makes the system a helpful instrument for patients and medical staff. The luminaire is equipped with two 230 V power sockets and three key switches.

Product information	Category Clean luminaires - surface		
	Family BHU LINEMED TRI	Family BHU LINEMED TRIANGLE LED	
	Name BHU LINEMED TRIANGLE LED P-4400-2200-ON-2-B-B-3-B E OPTICS-3L/PLX 53 840 L=1250MM		
	Index 19.4060.1221.53		
		$\begin{array}{c} \hline \\ \hline $	
Light and electrical data	Light source	LED	
	Luminous flux LED [lm]	6847,7	
	LED power [W]	31,6	
	Luminaire luminous flux [lm]	5010	
	Power of luminaire [W]	35,3	
	Luminaire's light efficiency [lm.	/W] 141,9	
	Color of the light [K]	4000	
	CRI	>80	
	SDCM (LED sources)	3	
	Beam angle [°]	asymmetric light distribution	
	Protection against electric sho	ck I	
	Protection degree	IP40	
	Voltage	220240 V, 5060 Hz	
	Lifetime of LED sources [h]	100000 (1) / 147000 (2)	
	Lx/By	L80/B10 (1) / L70/B10 (2)	
	Operating temperature range	[°C] 5÷30	
	Driver	standard on/off (E)	
	Power factor $\cos \varphi$	>0,95	
	Circuit load capacity	15 (B10), 24 (B16), 21 (C10), 35 (C16)	
Mechanical data	Assembly	mounted on wall	
.A	Material	steel sheet	
	Color	RAL 9003 (white)	
		OPTICS (optical system based on lenses) / PLX (PMMA opal)	
		IK04	
	Weight [kg]	5,98	
	Dimensions [mm]	1250 x 130 x 110	

A graph of light





Luminous flux tolerance +/- 10%. Power tolerance +/- 10%. Technical data may be changed. Photos of the luminaires may differ from reality. Date of last update: 24-01-2023