

## Product: AGAT CLEAN LED CRI95 7200 MICRO-PRM E IP65 940 / 600X600 Index: 19.4073.1341.34




## Description

Luxiona Poland as the only company in Europe has obtained CRI>95 for its luminaries (it provides high level of R9 and R13 that faithfully render the color of blood and tissue). Luminary recommended for operating theatres - lighting that is applied should faithfully render the color of blood, tissue, and skin (R9 responsible for rendering "deep red" color, and R13 responsible for rendering "light orange" color). Luminary designed to module and gypsum and cardboard suspended ceilings, equipped with the highly efficient LED panels. Luminary body made from steel sheet, powder coated in white. Optical systems and diffusers mounted in an aluminum frame.

| Product information       | CategoryClean luminaires CRI95FamilyAGAT CLEAN LED CRI95NameAGAT CLEAN LED CRI95 72Index19.4073.1341.34Image: Comparison of the comparison o | $\mathbb{P} \bigoplus \mathbb{P}_{65} \mathbb{K} \bigoplus \mathbb{P}_{65} \mathbb{K}$  |
|---------------------------|--|---|
| Light and electrical data | Light source<br>Luminous flux LED [lm]<br>LED power [W]<br>Luminaire luminous flux [lm]<br>Power of luminaire [W]<br>Luminaire's light efficiency [lm/W]<br>Color of the light [K]<br>CRI<br>SDCM (LED sources)<br>Beam angle [°]<br>Photobiological risk class (IEC/EN<br>62471)<br>Protection against electric shock<br>Protection degree<br>Voltage<br>Lifetime of LED sources [h]<br>Lx/By<br>Operating temperature range [°C]<br>Driver<br>Power factor cos φ   | LED<br>7833<br>49,6<br>5816<br>51,8<br>112,3<br>4000<br>>95<br>3<br>(C0-C180) / (C90-C270) - 89° / 89°<br>RG0<br>I<br>IP65<br>220240 V, 5060 Hz<br>100000 (1) / 147000 (2)<br>L80/B10 (1) / L70/B50 (2)<br>5 ÷ 30<br>standard on/off (E)<br>>0,95 |
|                           | Circuit load capacity  | 12 (B10), 20 (B16), 21 (C10), 34<br>(C16)   |





## Accessories

Index 2M-X414LKPIPT5 Name Mounting clips set for plasterboard ceiling



Luminous flux tolerance +/- 10%. Power tolerance +/- 10%. Technical data may be changed. Photos of the luminaires may differ from reality. Date of last update: 24-01-2023