

Product: AGAT CLEAN ISO NO FRAME LED CRI95 7200 SLMR E IP65 940 KRG3K / 600X600 Index: 19.4120.1241.34




Description

Luminary is recommended to be used in medical sector to illuminate such premises as: operating rooms, rooms designed for laparoscopic and endoscopic, surgeries and interventions, recovery rooms, dermatological offices and to illuminate blood collection centres, etc. Luminary designed to module suspended ceilings, equipped with highly efficient LED panels. Luminary body made from steel sheet, powder coated in white. Its characteristic feature is lack of aluminum frame what allows to exclude the unwished-for contamination in clean rooms. There are no visible elements joining the diffuser and the luminary body. This product is manufactured in production plant which holds quality management system for medical devices ISO 13485.

Product information	Category Recessed luminaires / CRI95 medical device Family AGAT CLEAN ISO NO FRAME LED CRI95		
		AGAT CLEAN ISO NO FRAME LED CRI95 7200 SLMR E IP65 940 KRG3K / 600X600	
		.1241.34	
Light and electrical data	Light source		LED
	Luminous flux LED) [lm]	7833
	LED power [W]		49,6
	Luminaire luminou	s flux [lm]	6276
	Power of luminaire	e [W]	51,8
	Luminaire's light e	fficiency [lm/W]	121,2
	Color of the light [I	<]	4000
	CRI		>95
	SDCM (LED source	es)	3
	Beam angle [°]		(C0-C180) / (C90-C270) - 100° / 100,2°
	Protection against	electric shock	1
	Protection degree		IP65
	Voltage		220240 V, 5060 Hz
	Lifetime of LED so	urces [h]	60000
	Lx/By		L80/B10
	Operating tempera	ature range [°C]	5 ÷ 30
	Driver		standard on/off (E)
	Power factor cos q)	>0,95
	Circuit load capaci	ty	16 (B10), 26 (B16), 23 (C10), 37 (C16)
Mechanical data	Assembly	mo	unted in module ceilings
	Material	ste	el sheet
	Color	whi	ite
	Diffuser	SLM	MR (laminated anti-reflective mat glass)
	Impact resistant	IK0	8
	Weight [kg]	6,68	8
	Dimensions [mm]	596	5 x 596 x 67



A graph of light



Accessories

Index 6BZBO60980



Luminous flux tolerance +/- 10%. Power tolerance +/- 10%. Technical data may be changed. Photos of the luminaires may differ from reality. Date of last update: 24-01-2023